



I hereby certify that this plan, specification or report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota

Aaron D. Hass

AARON D. HASS

Date 2-10-2025 Lic. No. 26424

NOTES:

1. SUBMIT PRODUCT SHOP DRAWINGS TO ENGINEER & CITY SEWERS DEPARTMENT FOR REVIEW
2. ROMAC CB SADDLE PER STANDARD PLATE NO. 2337 MAY BE USED IF ADJACENT SERVICES ARE IMPACTED OR DIRECTLY ACROSS
3. WHEN ANOTHER SERVICE LATERAL IS DIRECTLY ACROSS, REPLACE A PORTION OF THE MAINLINE WITH C900 PVC AND THEN CORE DRILL TWO NEW ROUND HOLES PER CITY STANDARD PLATES 2324, 2337(CURRENT VERSION)
4. CONTRACTOR TO INSTALL APPROVED PRODUCT PER MANUFACTURER SPECIFICATIONS

APPROVED 3/21/25 CITY ENGINEER	CITY OF ST. PAUL DEPARTMENT OF PUBLIC WORKS DIP WYE CONNECTION WITH SANITARY MAIN REPAIR	Date of Revision FEB 2025	Standard Plate No. 2340A